

Notice of Addenda

Addendum #2

Utah State University

Salt Lake Campus East Entrance Remodel

The following is a description of changes and clarifications to the bid documents for the USU Salt Lake Campus East Entrance Remodel Project.

- **Bid Date & Time:**
 - Bid date and is unchanged and remains the same.
- **Mechanical Clarifications (Mechanical Addendum #1 – Focus Mechanical Consulting):**
 - See attached document (Page 2)
 - Substitution request Approval - Boilers with 316 Stainless Steel heat exchangers are allowed as a substitute for cast iron.
- **Drawings & Specifications:**
 - No Chang



USU Salt Lake Campus East Entrance Remodel

Mechanical Addendum #1

6/3/22

Item #	Sheet/Specification	Description of Change
1	235216	Boilers with 316 Stainless Steel heat exchangers are allowed as a substitute for cast iron.

Prior Approvals : Note: If acceptable manufacturers for a type of product are not listed, any manufacturer that can meet the required specifications is allowed to bid. If acceptable manufacturers are listed, only those manufacturers are allowed to bid unless the list of acceptable manufacturers is modified below.

END OF ADDENDUM